



GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT



From
The District fire officer,
Rajendranagar Division.

To,
B.Seshagiri Rao,
Fortune Butterfly School.H.no.17-195 sy.no.736
And736/1.Fortune Butterfly City.Kadthal.RangaReddy,
,

Ack. No. **522620002024** Dated: **02/05/2024**

Sir,

Sub: **TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE DEPARTMENT**
–Rajendranagar Division. Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building of **Fortune Butterfly School, Fortune Butterfly School.H.no.17-195 sy.no.736 And 736/1.Fortune Butterfly City.Kadthal.RangaReddy, Telangana/-Kadthal/Kadthal/Rangareddy**, – Regarding.



Ref: 1. Acknowledgement No **522620002024**
2. This Office NOC for Occupancy Ack/RC No. **199250002019** dt. **02/05/2024**
3. Non Multi storeyed Building Inspection Committee Report,,
Ack. No. **522620002024**, dt. **02/05/2024**

1) The Non Multi storeyed Building Inspection committee, vide reference cited (3) has inspected the Non Multi storeyed Building of **Fortune Butterfly School, Fortune Butterfly School.H.no.17-195 sy.no.736 And 736/1.Fortune Butterfly City.Kadthal.RangaReddy, Telangana/-Kadthal/Kadthal/Rangareddy**

2) The above said building was issued was issued No Objection certificate vide reference cited (2) for Non Multi storeyed Building with **1 Ground, 2 Floors**, with a height of **10.95** Meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy .

3) Now the Builder/Authorized person has requested to issue Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building with **1 Ground, 2 Floors**, with a height of **10.95** Meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy

4) Open Spaces: The builder provided the following open spaces all around the building.

Sl.No	Side	Open spaces as per Noc occupancy	Open spaces provided now
a 1	North	8.00	8.00
2	South	6.00	6.00
3	East	6.00	6.00
4	West	6.00	6.00
b Sl. No	Gate Width As per Occupancy NOC	as per Noc occupancy	provided now
1	Entry gate width	6.00	6
2	Entry Gate Head Clearance	4.50	4.5
3	Exit Gate Width	6.00	6
4	Exit Gate Head Clearance	4.50	4.50

5) Travel Distance

Sl. No.	Item / Description	as per Noc occupancy	provided now
1	Farthest point (Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	19.00	19.00
2	The Dead end of the corridor length in exit access. (6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	4.00	4.00

6) Stair Cases (As per Occupancy NOC) :

Sl.no.	Type of staircases	Total width	No of staircases	Floors from	Floors to
--------	--------------------	-------------	------------------	-------------	-----------



GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT



1	Internal staircases	1.80	2	Ground	Terrace
2	External staircases	1.80	2	Ground	Terrace

7) Means of Escape Floor Wise Details :

Sl.no	Floor type	Buil-up Area in Sq.Mtrs	Type of Occupancy	Occupant Load	Means of escape required as per Occupancy NOC	Means escape available now
1	Ground	1546.05	EDUCATIONAL B-1 Schools up to senior secondary level	387.00	7.20	7.20
2	1st Floor	1546.05	EDUCATIONAL B-1 Schools up to senior secondary level	387.00	7.20	7.20
3	2nd Floor	1546.05	EDUCATIONAL B-1 Schools up to senior secondary level	387.00	7.20	7.20

8) Fire Shaft as per Occupancy NOC:

9) Floor Wise details of Fire Fighting Installations:

Sl.no	Floor Details	Fire Extinguisher	Hose Reel	Automatic Sprinklers System	Manually Operated Electronic Fire Alarm System	Automatic detection and alarm system
1	Ground	8.00	2.00	0.00	0.00	0.00
2	1st Floor	8.00	2.00	0.00	0.00	0.00
3	2nd Floor	8.00	2.00	0.00	0.00	0.00

10) Fire Fighting Installations As per Occupancy NOC :

Fire Fighting System.	Required As per Occupancy NOC	Provided
Fire Extinguishers	37	37
First Aid Hose Reel	9	9
Capacity of Terrace Tank over Respective Tower Terrace in Litres	10000	10000
Pump capacity in LPM at the Terrace Tank level with min Pressure of 3.5 Kg/CM ²	450	450
No. of Terrace Tanks over Respective Tower in ltrs	1	0
No. of Pumps at the Terrace Tank level with min pressure of 3.5 Kg/Cm ²	1	0

11). The Non Multi storeyed Building Inspection Committee have reported that the Management has provided the Fire Safety Measures and there is no deficiencies.

12. Remarks :

As per the recommendation of inspection committee the application is approved

13) In view of the above and as per recommendations of the Non Multi storeyed building inspection Committee, the Renewal of No Objection Certificate for occupancy is issued to Non Multi storeyed Building with **Fortune Butterfly School, Fortune Butterfly School. H.no.17-195 sy.no.736 And 736/1. Fortune Butterfly City. Kadthal. Ranga Reddy, Telangana/-Kadthal/Kadthal/Rangareddy**

with a height of **10.95** Meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy subject to the following conditions

Sl No	Builder and Management Body	Occupant	Management Body and fire and security personnel
.			



GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT



1	-a) All the fire protection arrangements shall be maintained in good condition as seen during inspection. -b) Do's and Don'ts in case of fire shall be prominently displayed in entire building	All the escape/exit roots shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting systems installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.	All occupants shall be trained to operate the fire safety equipment during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipment during emergency and guiding the occupants in safe evacuation. Call the fire Brigade by dialing 101.
4	This No objection Certificate for occupancy is valid for Five year from the date of issue of this letter.	Raise the alarm if the fire cannot be controlled, evacuate the area completely at once from the nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing doors and windows.

This Renewal of No Objection Certificate for Occupancy is valid for Five years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison – A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.



Signed By : T.Purnachander Rao
Designation : District Fire Officer , Ranga Reddy
Date : 02-05-2024
District fire officer,
Rajendranagar Division.

Copies to:

- i) The Management
- ii) Non Multi storeyed Building Inspection Committee
- iii) Copy submitted to Regional Fire officer
- iv) Copy submitted to DG fire services

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"



GOVERNMENT OF TELANGANA
FIRE, DISASTER RESPONSE, EMERGENCY & CIVIL DEFENCE DEPARTMENT
NO OBJECTION CERTIFICATE



From
The Regional Fire Officer ,Multi Zone-2,
Fire, Disaster Response, Emergency & Civil Defence
Department,
Telangana, Hyderabad.

To,
B.Seshagiri Rao,
BUTTERFLY SCHOOL BLOCK-B. SURVEY NO : 736,
736/1 & 736/AA,
SITUATED AT: KADTHAL VILLAGE & G.P,
KADTHAL MANDAL,
RANGA REDDY DISTRICT,
TELANGANA STATE.,

RC. No. **56014058702025** Dated:**09/02/2025**

Sir,

Su b: Telangana Fire, Disaster Response, Emergency & Civil Defence
Department –Rangareddy District. Issue of Revised Provisional No
Objection Certificate for proposed construction of Non Multi storied
Building of ,**BUTTERFLY SCHOOL BLOCK-B. SURVEY NO :
736,736/1 & 736/AA,SITUATED AT: KADTHAL VILLAGE &
G.P,KADTHAL MANDAL,RANGA REDDY
DISTRICT,TELANGANA STATE./-Kadthal/Kadthal/Rangareddy,**
Hyderabad – Regarding.

Ref 1. Provisional NOC Acknowledgement No **448700002022**
. 2. Report of the Multi-Storeyed Building Inspection Committee, Hyderabad
Rc. No.**56014058702025**, dt. **09/02/2025** .
3. Judgement dated 28.9.2006 of the Hon'ble High Court of A. P. in W.P.
M.P. No.21991 of 2006 in W. P. No. 26365 of 2005.



1. The Provisional No Objection Certificate vide reference 1st cited has been issued to the proposed Non Multi Storeyed Building of ,**BUTTERFLY SCHOOL BLOCK-B. SURVEY NO : 736,736/1 & 736/AA,SITUATED AT: KADTHAL VILLAGE & G.P,KADTHAL MANDAL,RANGA REDDY DISTRICT,TELANGANA STATE./- Kadthal/Kadthal/Rangareddy**

2) Now, the applicant has submitted application for issue of Revised Provisional NOC to the above said proposed Non Multi Storeyed Building of **Ground, 3 Floors**, floors with a height of **13.61** meters

3) The Multi Storeyed Building Inspection committee , vide reference 2nd cited have inspected the proposed Non Multi Storeyed Building of ,**BUTTERFLY SCHOOL BLOCK-B. SURVEY NO : 736,736/1 & 736/AA,SITUATED AT: KADTHAL VILLAGE & G.P,KADTHAL MANDAL,RANGA REDDY DISTRICT,TELANGANA STATE./- Kadthal/Kadthal/Rangareddy**

4) Vide reference cited (3), the Hon'ble High Court has directed that:

- “Since the Department has carried out necessary inspection and has found nothing objectionable, we give liberty to the concerned authority to issue no objection certificate to the applicant subject to the condition that if the applicants makes any deviation from the sanctioned plan, then the competent authority shall be entitled to demolish the entire building irrespective of the stage of construction.

- The department has in last more than six months rigorously ensured total adherence to the norms prescribed and the relevant statutory provisions made for taking fire safety measures, we deem it proper to modify order dated 21.3.2006 and direct that the competent authority shall be free to consider and decide the applications made in further for grant of No Objection Certificate under the Telangana Fire Service Act, 1999 after clearance by the Multi-storeyed Building Inspection Committee.”

5) The Multi-Storeyed Building Inspection Committee, Telangana Fire Services Department vide reference cited (2) has recommended for the issuance of Revised No Objection Certificate to the proposed Non Multi-Storeyed Building with **Ground, 3 Floors**, floors with a height of **13.61** meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy being constructed by **B.Seshagiri Rao,BUTTERFLY SCHOOL BLOCK-B. SURVEY NO : 736,736/1 & 736/AA,SITUATED AT: KADTHAL VILLAGE & G.P,KADTHAL MANDAL,RANGA REDDY**



GOVERNMENT OF TELANGANA
FIRE, DISASTER RESPONSE, EMERGENCY & CIVIL DEFENCE DEPARTMENT
NO OBJECTION CERTIFICATE



DISTRICT, TELANGANA STATE..

6) In pursuance of the orders of the Hon'ble High Court cited above, the Revised No Objection Certificate is issued to the proposed Non Multi-Storeyed Building, **BUTTERFLY SCHOOL BLOCK-B. SURVEY NO : 736,736/1 & 736/AA, SITUATED AT: KADTHAL VILLAGE & G.P, KADTHAL MANDAL, RANGA REDDY DISTRICT, TELANGANA STATE./-Kadthal/Kadthal/Rangareddy** with a height of **13.61** metres for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy being constructed M/s. **B.Seshagiri Rao, 8501905566, BUTTERFLY SCHOOL BLOCK-B. SURVEY NO : 736,736/1 & 736/AA, SITUATED AT: KADTHAL VILLAGE & G.P, KADTHAL MANDAL, RANGA REDDY DISTRICT, TELANGANA STATE.,** as per Section 13 (1) of Telangana Fire Service Act, 1999.

7) The Builder has to follow the following Act/Rules/Regulations :

I. Telangana Fire Service Act, 1999 :

As per Section 31 of "whoever willfully contravenes any provisions of this Act or the rules made there under or fails to comply with any requisition lawfully made upon him under any provisions of this Act shall, without prejudice to any other action taken against him under Section 22 be punishable with imprisonment for a term which may extend to three months or with fine which may extend to twenty five thousand rupees or with both; and where the offence is a continuing one, with a further fine which may extend to three thousand rupees for every day during which such offence continues after the conviction for the first such offence.

II. Municipal Corporation Building Bye-Laws, 1981 :

As per Bye-Law 12 "On completion of the building work, the licensed technical personnel shall give notice to the Authority in prescribed form in pursuance of sub-section (1) of Section 455 of the Act." The Builder, on completion of the Building and before occupation, should intimate the Director General of Fire Services for inspection and issue of "No Objection Certificate". As per Bye-law 13.1 "No building erected, re-erected or altered materially shall be occupied in whole or in part until the issue of an Occupancy Certificate by the authority affirming that such building is fit for occupation".

III. National Building Code of India :

As per Clause 13.1 of Part-II of the National Building Code of India "neither granting of the permit nor the approval of the drawings and specifications, nor inspections made by the Authority during erection of the building shall in any way relieve the owner of such building from full responsibility for carrying out the work in accordance with the requirements of the National Building Code of India." The building should not be occupied without "No Objection Certificate" from the Fire Services Department.

IV. . As per Clause 9.1.3 of Part II of the National Building Code of India "the Licensed Architect/Engineer/Structural Engineer/Supervisor/Town Planner shall be responsible for supervision of the construction and for the completion certificate. In the event of violation of the provisions of the code he shall be liable to penalties as prescribed by the Authority including cancellation of the Licence".

VI. G.O.Ms.No.168 MA&UD (M1) Department, dt. 07/04/2012.

15 a. (i) The building requirements and standards other than heights and setbacks specified in the National Building Code - 2005 shall be complied with.

(ii) Such buildings shall be undertaken by owners by engaging registered architect, licenced builders / developers and licenced structural engineers. The designs and building plans shall be countersigned by the owner, licenced developer, registered architect, licenced engineer and a qualified & licenced Structural Engineer who shall be responsible for the supervision, structural safety, fire safety and specifications compliance of such buildings.

(iii) The work of the building services like sanitation, plumbing, fire safety requirements, lifts, electrical installations, and other utility services shall be executed under the planning, design and supervision of qualified and competent technical personnel.

The builder has requested to issue **Revised Provisional No Objection certificate** vide reference cite for construction of Non Multi Storeyed Building with **Ground, 3 Floors,** floors with a height of **13.61** Meters for **EDUCATIONAL B-1**



GOVERNMENT OF TELANGANA
FIRE, DISASTER RESPONSE, EMERGENCY & CIVIL DEFENCE DEPARTMENT
NO OBJECTION CERTIFICATE



Schools up to senior secondary level.

8. Open Spaces & Gate Width:

SL.No	Open Spaces (in Meters as per 8.3.1a of Part 4 NBC 2016)	Required	Proposed
a) 1	North	6.00	8.00
2	South	6.00	6.00
3	East	6.00	6.00
4	West	6.00	6.00
b SL. No	Gate Width As per NBC 2016	Required	Proposed
1	Entry gate width	6.00	6
2	Entry Gate Head Clearance	4.50	4.5
3	Exit Gate Width	6.00	6
4	Exit Gate Head Clearance	4.50	4.50

9. Travel Distance

Sl. No.	Item / Description	Required (Not More than in Mtrs.)	Proposed
1	Farthest point (Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	30.00	30.00
2	The Dead end of the corridor length in exit access. (Not to exceed 6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	6.00	6.00

10. Stair Cases (As per NBC 2016)

Sl.no	Type of staircases	Width (In Mtrs)	No of staircases	Floors from	Floors to
1	Internal staircases	1.50	1	Ground	Terrace
2	External staircases	1.50	1	Ground	Terrace

11. Means of Escape (Stair Cases) Floor Wise Details

Sl.no	Floor type	Buil-up Area in Sq.Mtrs	Type of Occupancy	Occupant Load	Means of escape required as per table 21 of NBC	Means of escape proposed
1	Ground	659.53	EDUCATIONAL B-1 Schools up to senior secondary level	165.00	1.65	5.00
2	1st Floor	659.53	EDUCATIONAL B-1 Schools up to senior secondary level	165.00	1.65	3.00
3	2nd Floor	659.53	EDUCATIONAL B-1 Schools up to senior secondary level	165.00	1.65	3.00
4	3rd Floor	659.53	EDUCATIONAL B-1 Schools up to senior secondary level	165.00	1.65	3.00
	Total	2638.12				

12. Floor Wise details of Fire Fighting Installations Proposed.

Sl.no	Floor Details	Fire Extinguisher	Hose Reel	Automatic Sprinklers System	Manually Operated Electronic Fire Alarm System	Automatic detection and alarm system
1	Ground	4.00	1.00	0.00	0.00	0.00
2	1st Floor	4.00	1.00	0.00	0.00	0.00
3	2nd	4.00	1.00	0.00	0.00	0.00



GOVERNMENT OF TELANGANA
FIRE, DISASTER RESPONSE, EMERGENCY & CIVIL DEFENCE DEPARTMENT
NO OBJECTION CERTIFICATE



	Floor					
4	3rd Floor	4.00	1.00	0.00	0.00	0.00

13. Fire Fighting Installations as per Table 7 of NBC 2016:

Fire Fighting System.	Required As per NBC	Proposed
Fire Extinguishers	16.00	25
First Aid Hose Reel	4.00	4
Yard Hydrant	3.00	0
Capacity of Terrace Tank over Respective Tower Terrace in Litres	10000.00	10000
Pump capacity in LPM at the Terrace Tank level with min Pressure of 3.5 Kg/CM ²	450.00	450
No. of Terrace Tanks over Respective Tower in ltrs	1	1
No. of Pumps at the Terrace Tank level with min pressure of 3.5 Kg/Cm ²	1	1

14. The builder has proposed to provide the following additional Fire Safety Requirements as per NBC part 4 of India 2016::

Sl. No	Fire safety Item
1.	Open spaces all around the building shall be Leveled and have hard spaces for operation of fire vehicles.
2.	The upper floors of the educational building shall be provided with exits for every travel distance of 30 meters (TYPE1 & 2 constructions) as per table5 under clause 4.4.2.1, 4.4.2.2 of Part IV of NBC 2016
3.	The width of all exit door ways has to be 01-00 meter and 02-00 meters in respect of Assembly halls as per clause 8.1 of IS 14435:1997
4.	The height of exit door ways has to be 02-00 meters and more, as per clause of 8.2 of IS 14435:1997
5.	A minimum number of two separate exits have to be provided for each floor as per clause 6.2 of IS 14435:1997
6.	The exits shall be remote from each other as practicable as per clause 6.2 of IS 14435:1997
7.	At least 02 Doorways are proposed for every room with a capacity of over 45 persons As per clause 6.2.2(a) of part-IV of NBC-2016
8.	The Location of Rooms of Preschool, Kindergarten, Class/Grade 1 student have to be at Ground Floor/level only and Class/Grade II student at ground or First Floor only
9.	The building has to be suitably Compartmented and provided with smoke control measures so that fire / smoke remains confined to the area where fire incident has occurred and does not spread to the remaining part of the building as per Clause 4.5 and 4.6 of part 4 NBC of India 2016.
10.	Floor Openings Fire Protection are to be Complied As per Clause 3.4.5.
	a) Openings in Service ducts and shafts allowing building services like cables, Electrical wirings, Telephone cables, plumbing pipes etc., shall be protected by enclosure in the form of ducts / shaft having a fire resistant's not less than 120 min.
	b) The inspection door for electrical shafts / ducts shall be not less than 120 min.
	c) Medium and low voltage wiring running in shafts / ducts shall either be armoured type or run through metal conduits.
	d) The space between the electrical cables/conduits and the walls/slabs shall be filled in by a fire stop material having fire resistance rating of not less than 120 min. This shall exclude requirement of fire stop sealing for low voltage services shaft.
	e) For plumbing shafts in the core of the building, with shaft door opening inside the building, the shafts shall have inspection doors having fire resistance rating not less than 30 min..
11.	Vertical openings Fire Protection are to be Complied with as per Clause- 3.4.5.6 Every vertical opening



GOVERNMENT OF TELANGANA
FIRE, DISASTER RESPONSE, EMERGENCY & CIVIL DEFENCE DEPARTMENT
NO OBJECTION CERTIFICATE



	between the floors of a building shall be suitably enclosed or protected, as necessary, to provide the following:
	a) Reasonable safety to the occupants while using the means of egress by preventing spread of fire, smoke, or fumes through vertical openings from floor to floor to allow occupants to complete their use of the means of egress. Further it shall be ensured to provide a clear height of 2 100 mm in the exit access.
	b) Limitation of damage to the building and its contents.
12.	Electrical safety is to be complied with as per Clause 3.4.6 of part – 4 NBC of India 2016
12.	a) Whether the wiring and cabling are having flame retardant property. Medium and low voltage wiring running in shafts and within false ceiling shall run in metal conduit. Any 230 V wiring for lighting or other services, above false ceiling, shall have 660 V grade insulation
	b) Whether the electric distribution cables/wiring shall be laid in a separate shaft. The shaft shall be sealed at every floor with fire stop materials having the same fire resistance as that of the floor. High, medium and low voltage wiring running in shaft and in false ceiling shall run in separate shaft/conduits.
	c) water mains, gas pipes, telephone lines, intercom lines or any other service line shall not be laid in the duct for electrical cables; use of bus ducts/solid rising mains instead of cables is preferred.
	d) Whether all metallic items like steel structural members, etc, shall be bonded properly to the earthing system.
13.	Lightning protection of buildings is to be Complied with as per clause – 3.4.6.5 Routing of down conductors (insulated or uninsulated) of lightning protection through electrical or other service shafts are not allowed as it can create fire and explosion during lightning. For details, see Part 8 Building Services, Section 2 Electrical and Allied Installations' of the Code
14.	Escape Lighting and Exit Signage is to be Complied with as per Clause 3.4.7 Exit access, exits and exit discharge shall be properly identified, with adequate lighting maintained in the elements of the egress systems so that all occupants shall be able to leave the facility safely.
15.	Lighting is to be Complied with as per Clause – 3.4.7.1
	i) The exit, exit access and exit discharge systems shall be illuminated continuously. The floors of the means of egress shall be illuminated at all points, including angles and intersections, in corridors and passageways, stairwells, landings of stairwells and exit.
	ii) Emergency lighting shall be powered from a source independent of that supplying the normal lighting.
	iii) The emergency lighting shall be provided to be put on within 5 s of the failure of the normal lighting supply. Also, emergency lighting shall be able to maintain the required illumination level for a period of not less than 90 min in the event of failure of the normal lighting even for smaller premises.
	iv) Signs are required at all exits, emergency exits and escape routes, which should comply with the graphic requirements of the relevant Indian Standards
16.	Exit passageway (at ground) and staircase lighting is to be connected to alternative supply. The alternative source of supply may be provided by battery continuously trickle charged from the electric mains as per clause – 3.4.7.2
17.	Number of exits, Arrangements of exits and capacities of Means of egress types of exit access and exits etc., shall be complied with as per Clause 4.4.2 of part – 4 NBC of India 2016
18.	Smoke control of exits are shall be complied with as per Clause 4.4 2.5 of part – 4 NBC of India 2016
19.	Fire Drills and Fire orders are to be Complied with as per Clause 4.11 of part – 4 NBC of India 2016 Fire notices/orders shall be prepared to fulfil the requirements of firefighting and evacuation from the buildings in the event of fire and other emergency. The occupants shall be made thoroughly conversant with their action in the event of emergency, by displaying fire notices at vantage points and also through regular training. Such notices should be displayed prominently in bold lettering. For guidelines for fire drills and evacuation procedures for high rise buildings, see Annex D
20.	Fire extinguishers / fixed fire fighting installations, static water storage tanks and pump house are to be Complied with as per Clause 5.1 of part – 4 NBC of India 2016
21.	Automatic sprinkler installation shall be proposed as per Clause 5.1.3 of part – 4 NBC of India 2016 (If Basement exceeds 200 sq. Mtr. Area)
22.	Fire Safety plans shall be prepared and submitted at the time of occupancy by the builder.
23.	Fire Drills shall be conducted with accordance with the fire safety plan at least once in every 03 months for building during the first 02 Years and there after once in 6 months as per Clause D-3 in annex. D of Part IV NBC of India 2016.



GOVERNMENT OF TELANGANA
FIRE, DISASTER RESPONSE, EMERGENCY & CIVIL DEFENCE DEPARTMENT
NO OBJECTION CERTIFICATE



15. It is informed that, you may please note that the builder along with Architect and site Engineer shall be held responsible for any deviations from the Revised provisional No Objection Certificate issued and necessary Legal Action will be initiated as per provisions of Fire Service Act.

16. The Revised Provisional No Objection Certificate is issued with an advice that Non Multi Storied Building should not be occupied and the operation should not be commenced without obtaining the No Objection certificate for occupancy from this Department about the satisfactory installation of above fire safety measures.

Hence Provisional No Objection Certificate issued earlier vide reference 1st cited is cancelled.

17. Additional Fire Safety Measures Recommended by the Department:

0



Signed By : B.Harinatha Reddy

Designation : Regional Fire Officer, Multi Zone-2.

Date : 09-02-2025

Fire, Disaster Response, Emergency & Civil Defence Department,
Telangana, Hyderabad.

Copies to:

- i) The Management
- ii) Multistoried Building Inspection Committee
- iii) Copy submitted to Regional Fire officer
- iv) Copy submitted to DG fire services

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"



GOVERNMENT OF TELANGANA
FIRE, DISASTER RESPONSE, EMERGENCY & CIVIL DEFENCE DEPARTMENT
NO OBJECTION CERTIFICATE



From
The Regional Fire Officer ,Multi Zone-2,
Fire, Disaster Response, Emergency & Civil Defence
Department,
Telangana, Hyderabad.

To,
Battula Seshagiri Rao,
FORTUNE BUTTERFLY SCHOOL BLOCK-C,
SY.No. : 736,
736/1 & 736/AA,
SITUATED AT KADTHALVILLAGE & G.P,
KADTHAL MANDAL,
RANGA REDDY DIST.,

RC. No. **448690002022** Dated:**09/02/2025**

Sir,

Su b: Telangana Fire, Disaster Response, Emergency & Civil Defence
Department –Rangareddy District. Issue of Revised Provisional No
Objection Certificate for proposed construction of Non Multi storied
Building of **FORTUNE BUTTERFLY SCHOOL BLOCK-C,FORTUNE BUTTERFLY SCHOOL BLOCK-C,SY.No. : 736, 736/1
& 736/AA, SITUATED AT KADTHALVILLAGE & G.P, KADTHAL
MANDAL,RANGA REDDY DIST./-Kadthal/Kadthal/Rangareddy,**
Hyderabad – Regarding.

Ref 1. Provisional NOC Acknowledgement No **525530002024**
. 2. Report of the Multi-Storeyed Building Inspection Committee, Hyderabad
Rc. No.**448690002022**, dt. **09/02/2025** .
3. Judgement dated 28.9.2006 of the Hon'ble High Court of A. P. in W.P.
M.P. No.21991 of 2006 in W. P. No. 26365 of 2005.



1. The Provisional No Objection Certificate vide reference 1st cited has been issued to the proposed Non Multi Storeyed Building of **FORTUNE BUTTERFLY SCHOOL BLOCK-C,FORTUNE BUTTERFLY SCHOOL BLOCK-C,SY.No. : 736, 736/1 & 736/AA, SITUATED AT KADTHALVILLAGE & G.P, KADTHAL MANDAL,RANGA REDDY DIST./-Kadthal/Kadthal/Rangareddy**

2) Now, the applicant has submitted application for issue of Revised Provisional NOC to the above said proposed Non Multi Storeyed Building of **1 Cellars, Ground, 3 Floors,** floors with a height of **13.61** meters

3) The Multi Storeyed Building Inspection committee , vide reference 2nd cited have inspected the proposed Non Multi Storeyed Building of **FORTUNE BUTTERFLY SCHOOL BLOCK-C,FORTUNE BUTTERFLY SCHOOL BLOCK-C,SY.No. : 736, 736/1 & 736/AA, SITUATED AT KADTHALVILLAGE & G.P, KADTHAL MANDAL,RANGA REDDY DIST./-Kadthal/Kadthal/Rangareddy**

4) Vide reference cited (3), the Hon'ble High Court has directed that:

- “Since the Department has carried out necessary inspection and has found nothing objectionable, we give liberty to the concerned authority to issue no objection certificate to the applicant subject to the condition that if the applicants makes any deviation from the sanctioned plan, then the competent authority shall be entitled to demolish the entire building irrespective of the stage of construction.

- The department has in last more than six months rigorously ensured total adherence to the norms prescribed and the relevant statutory provisions made for taking fire safety measures, we deem it proper to modify order dated 21.3.2006 and direct that the competent authority shall be free to consider and decide the applications made in further for grant of No Objection Certificate under the Telangana Fire Service Act, 1999 after clearance by the Multi-storeyed Building Inspection Committee.”

5) The Multi-Storeyed Building Inspection Committee, Telangana Fire Services Department vide reference cited (2) has recommended for the issuance of Revised No Objection Certificate to the proposed Non Multi-Storeyed Building with **1 Cellars, Ground, 3 Floors,** floors with a height of **13.61** meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy being constructed by **Battula Seshagiri Rao,FORTUNE BUTTERFLY SCHOOL BLOCK-C,SY.No. : 736, 736/1 & 736/AA, SITUATED AT KADTHALVILLAGE & G.P, KADTHAL**



GOVERNMENT OF TELANGANA
FIRE, DISASTER RESPONSE, EMERGENCY & CIVIL DEFENCE DEPARTMENT
NO OBJECTION CERTIFICATE



MANDAL,RANGA REDDY DIST..

6) In pursuance of the orders of the Hon'ble High Court cited above, the Revised No Objection Certificate is issued to the proposed Non Multi-Storeyed Building **FORTUNE BUTTERFLY SCHOOL BLOCK-C,FORTUNE BUTTERFLY SCHOOL BLOCK-C,SY.No. : 736, 736/1 &736/AA, SITUATED AT KADTHALVILLAGE & G.P, KADTHAL MANDAL,RANGA REDDY DIST./-Kadthal/Kadthal/Rangareddy** with a height of **13.61** metres for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy being constructed M/s.**Battula Seshagiri Rao,8501905566,FORTUNE BUTTERFLY SCHOOL BLOCK-C,SY.No. : 736, 736/1 &736/AA, SITUATED AT KADTHALVILLAGE & G.P, KADTHAL MANDAL,RANGA REDDY DIST.,** as per Section 13 (1) of Telangana Fire Service Act, 1999.

7) The Builder has to follow the following Act/Rules/Regulations :

I. Telangana Fire Service Act, 1999 :

As per Section 31 of "whoever willfully contravenes any provisions of this Act or the rules made there under or fails to comply with any requisition lawfully made upon him under any provisions of this Act shall, without prejudice to any other action taken against him under Section 22 be punishable with imprisonment for a term which may extend to three months or with fine which may extend to twenty five thousand rupees or with both; and where the offence is a continuing one, with a further fine which may extend to three thousand rupees for every day during which such offence continues after the conviction for the first such offence.

II. Municipal Corporation Building Bye-Laws, 1981 :

As per Bye-Law 12 "On completion of the building work, the licensed technical personnel shall give notice to the Authority in prescribed form in pursuance of sub-section (1) of Section 455 of the Act." The Builder, on completion of the Building and before occupation, should intimate the Director General of Fire Services for inspection and issue of "No Objection Certificate". As per Bye-law 13.1 "No building erected, re-erected or altered materially shall be occupied in whole or in part until the issue of an Occupancy Certificate by the authority affirming that such building is fit for occupation".

III. National Building Code of India :

As per Clause 13.1 of Part-II of the National Building Code of India "neither granting of the permit nor the approval of the drawings and specifications, nor inspections made by the Authority during erection of the building shall in any way relieve the owner of such building from full responsibility for carrying out the work in accordance with the requirements of the National Building Code of India." The building should not be occupied without "No Objection Certificate" from the Fire Services Department.

IV. . As per Clause 9.1.3 of Part II of the National Building Code of India "the Licensed Architect/Engineer/Structural Engineer/Supervisor/Town Planner shall be responsible for supervision of the construction and for the completion certificate. In the event of violation of the provisions of the code he shall be liable to penalties as prescribed by the Authority including cancellation of the Licence".

VI. G.O.Ms.No.168 MA&UD (M1) Department, dt. 07/04/2012.

15 a. (i) The building requirements and standards other than heights and setbacks specified in the National Building Code - 2005 shall be complied with.

(ii) Such buildings shall be undertaken by owners by engaging registered architect, licenced builders / developers and licenced structural engineers. The designs and building plans shall be countersigned by the owner, licenced developer, registered architect, licenced engineer and a qualified & licenced Structural Engineer who shall be responsible for the supervision, structural safety, fire safety and specifications compliance of such buildings.

(iii) The work of the building services like sanitation, plumbing, fire safety requirements, lifts, electrical installations, and other utility services shall be executed under the planning, design and supervision of qualified and competent technical personnel.

The builder has requested to issue **Revised Provisional No Objection certificate** vide reference cite for construction of Non Multi Storeyed Building with **1 Cellars, Ground, 3 Floors,** floors with a height of **13.61** Meters for



GOVERNMENT OF TELANGANA
FIRE, DISASTER RESPONSE, EMERGENCY & CIVIL DEFENCE DEPARTMENT
NO OBJECTION CERTIFICATE



EDUCATIONAL B-1 Schools up to senior secondary level.

8. Open Spaces & Gate Width:

SL.No	Open Spaces (in Meters as per 8.3.1a of Part 4 NBC 2016)	Required	Proposed
a) 1	North	6.00	6.00
2	South	6.00	6.00
3	East	6.00	6.00
4	West	6.00	6.00
b SL. No	Gate Width As per NBC 2016	Required	Proposed
1	Entry gate width	6.00	6
2	Entry Gate Head Clearance	4.50	4.5
3	Exit Gate Width	6.00	6
4	Exit Gate Head Clearance	4.50	4.50

9. Travel Distance

Sl. No.	Item / Description	Required (Not More than in Mtrs.)	Proposed
1	Farthest point (Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	30.00	29.54
2	The Dead end of the corridor length in exit access. (Not to exceed 6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	6.00	3.18

10. Stair Cases (As per NBC 2016)

Sl.no	Type of staircases	Width (In Mtrs)	No of staircases	Floors from	Floors to
1	Internal staircases	1.78	1	Ground	Terrace
2	External staircases	1.50	2	Ground	Terrace
3	Ramp(Used for Movement of vehicles)	3.66	1	Cellar	Ground

11. Means of Escape (Stair Cases) Floor Wise Details

Sl.no	Floor type	Buil-up Area in Sq.Mtrs	Type of Occupancy	Occupant Load	Means of escape required as per table 21 of NBC	Means of escape proposed
1	Cellar	258.43	Parking	9.00	0.09	7.32
2	Ground	870.18	EDUCATIONAL B-1 Schools up to senior secondary level	218.00	2.18	4.78
3	1st Floor	870.18	EDUCATIONAL B-1 Schools up to senior secondary level	218.00	2.18	4.78
4	2nd Floor	870.18	EDUCATIONAL B-1 Schools up to senior secondary level	218.00	2.18	4.78
5	3rd Floor	870.18	EDUCATIONAL B-1 Schools up to senior secondary level	218.00	2.18	4.78
	Total	3739.15				

12. Floor Wise details of Fire Fighting Installations Proposed.

Sl.no	Floor Details	Fire Extinguisher	Hose Reel	Automatic Sprinklers System	Manually Operated Electronic Fire Alarm System	Automatic detection and alarm system
1	Cellar	2.00	1.00	29.00	0.00	0.00



GOVERNMENT OF TELANGANA
FIRE, DISASTER RESPONSE, EMERGENCY & CIVIL DEFENCE DEPARTMENT
NO OBJECTION CERTIFICATE



2	Ground	5.00	1.00	0.00	0.00	0.00
3	1st Floor	5.00	1.00	0.00	0.00	0.00
4	2nd Floor	5.00	1.00	0.00	0.00	0.00
5	3rd Floor	5.00	1.00	0.00	0.00	0.00

13. Fire Fighting Installations as per Table 7 of NBC 2016:

Fire Fighting System.	Required As per NBC	Proposed
Fire Extinguishers	22.00	40
First Aid Hose Reel	5.00	9
Yard Hydrant	2.00	0
Automatic Sprinkler System	29.00	29
Capacity of Terrace Tank over Respective Tower Terrace in Litres	10000.00	15000
Pump capacity in LPM at the Terrace Tank level with min Pressure of 3.5 Kg/CM ²	450.00	900
No. of Terrace Tanks over Respective Tower in ltrs	1	1
No. of Pumps at the Terrace Tank level with min pressure of 3.5 Kg/Cm ²	1	1

14. The builder has proposed to provide the following additional Fire Safety Requirements as per NBC part 4 of India 2016::

Sl. No	Fire safety Item
1.	Open spaces all around the building shall be Leveled and have hard spaces for operation of fire vehicles.
2.	The upper floors of the educational building shall be provided with exits for every travel distance of 30 meters (TYPE1 & 2 constructions) as per table 5 under clause 4.4.2.1, 4.4.2.2 of Part IV of NBC 2016
3.	The width of all exit door ways has to be 01-00 meter and 02-00 meters in respect of Assembly halls as per clause 8.1 of IS 14435:1997
4.	The height of exit door ways has to be 02-00 meters and more, as per clause of 8.2 of IS 14435:1997
5.	A minimum number of two separate exits have to be provided for each floor as per clause 6.2 of IS 14435:1997
6.	The exits shall be remote from each other as practicable as per clause 6.2 of IS 14435:1997
7.	At least 02 Doorways are proposed for every room with a capacity of over 45 persons As per clause 6.2.2(a) of part-IV of NBC-2016
8.	The Location of Rooms of Preschool, Kindergarten, Class/Grade 1 student have to be at Ground Floor/level only and Class/Grade II student at ground or First Floor only
9.	The building has to be suitably Compartmented and provided with smoke control measures so that fire / smoke remains confined to the area where fire incident has occurred and does not spread to the remaining part of the building as per Clause 4.5 and 4.6 of part 4 NBC of India 2016.
10.	Floor Openings Fire Protection are to be Complied As per Clause 3.4.5.
	a) Openings in Service ducts and shafts allowing building services like cables, Electrical wirings, Telephone cables, plumbing pipes etc., shall be protected by enclosure in the form of ducts / shaft having a fire resistant's not less than 120 min.
	b) The inspection door for electrical shafts / ducts shall be not less than 120 min.
	c) Medium and low voltage wiring running in shafts / ducts shall either be armoured type or run through metal conduits.
	d) The space between the electrical cables/conduits and the walls/slabs shall be filled in by a fire stop material having fire resistance rating of not less than 120 min. This shall exclude requirement of fire stop sealing for low



GOVERNMENT OF TELANGANA
FIRE, DISASTER RESPONSE, EMERGENCY & CIVIL DEFENCE DEPARTMENT
NO OBJECTION CERTIFICATE



	voltage services shaft.
	e) For plumbing shafts in the core of the building, with shaft door opening inside the building, the shafts shall have inspection doors having fire resistance rating not less than 30 min..
11.	Vertical openings Fire Protection are to be Complied with as per Clause- 3.4.5.6 Every vertical opening between the floors of a building shall be suitably enclosed or protected, as necessary, to provide the following:
	a) Reasonable safety to the occupants while using the means of egress by preventing spread of fire, smoke, or fumes through vertical openings from floor to floor to allow occupants to complete their use of the means of egress. Further it shall be ensured to provide a clear height of 2 100 mm in the exit access.
	b) Limitation of damage to the building and its contents.
12.	Electrical safety is to be complied with as per Clause 3.4.6 of part – 4 NBC of India 2016
12.	a) Whether the wiring and cabling are having flame retardant property. Medium and low voltage wiring running in shafts and within false ceiling shall run in metal conduit. Any 230 V wiring for lighting or other services, above false ceiling, shall have 660 V grade insulation
	b) Whether the electric distribution cables/wiring shall be laid in a separate shaft. The shaft shall be sealed at every floor with fire stop materials having the same fire resistance as that of the floor. High, medium and low voltage wiring running in shaft and in false ceiling shall run in separate shaft/conduits.
	c) water mains, gas pipes, telephone lines, intercom lines or any other service line shall not be laid in the duct for electrical cables; use of bus ducts/solid rising mains instead of cables is preferred.
	d) Whether all metallic items like steel structural members, etc, shall be bonded properly to the earthing system.
13.	Lightning protection of buildings is to be Complied with as per clause – 3.4.6.5 Routing of down conductors (insulated or uninsulated) of lightning protection through electrical or other service shafts are not allowed as it can create fire and explosion during lightning. For details, see Part 8 Building Services, Section 2 Electrical and Allied Installations' of the Code
14.	Escape Lighting and Exit Signage is to be Complied with as per Clause 3.4.7 Exit access, exits and exit discharge shall be properly identified, with adequate lighting maintained in the elements of the egress systems so that all occupants shall be able to leave the facility safely.
15.	Lighting is to be Complied with as per Clause – 3.4.7.1
	i) The exit, exit access and exit discharge systems shall be illuminated continuously. The floors of the means of egress shall be illuminated at all points, including angles and intersections, in corridors and passageways, stairwells, landings of stairwells and exit.
	ii) Emergency lighting shall be powered from a source independent of that supplying the normal lighting.
	iii) The emergency lighting shall be provided to be put on within 5 s of the failure of the normal lighting supply. Also, emergency lighting shall be able to maintain the required illumination level for a period of not less than 90 min in the event of failure of the normal lighting even for smaller premises.
	iv) Signs are required at all exits, emergency exits and escape routes, which should comply with the graphic requirements of the relevant Indian Standards
16.	Exit passageway (at ground) and staircase lighting is to be connected to alternative supply. The alternative source of supply may be provided by battery continuously trickle charged from the electric mains as per clause – 3.4.7.2
17.	Number of exits, Arrangements of exits and capacities of Means of egress types of exit access and exits etc., shall be complied with as per Clause 4.4.2 of part – 4 NBC of India 2016
18.	Smoke control of exits are shall be complied with as per Clause 4.4 2.5of part – 4 NBC of India 2016
19.	Fire Drills and Fire orders are to be Complied with as per Clause 4.11 of part – 4 NBC of India 2016 Fire notices/orders shall be prepared to fulfil the requirements of firefighting and evacuation from the buildings in the event of fire and other emergency. The occupants shall be made thoroughly conversant with their action in the event of emergency, by displaying fire notices at vantage points and also through regular training. Such notices should be displayed prominently in bold lettering. For guidelines for fire drills and evacuation procedures for high rise buildings, see Annex D
20.	Fire extinguishers / fixed fire fighting installations, static water storage tanks and pump house are to be Complied with as per Clause 5.1 of part – 4 NBC of India 2016
21.	Automatic sprinkler installation shall be proposed as per Clause 5.1.3 of part – 4 NBC of India 2016 (If Basement exceeds 200 sq. Mtr. Area)
22.	Fire Safety plans shall be prepared and submitted at the time of occupancy by the builder.
23.	Fire Drills shall be conducted with accordance with the fire safety plan at least once in every 03 months for



GOVERNMENT OF TELANGANA
FIRE, DISASTER RESPONSE, EMERGENCY & CIVIL DEFENCE DEPARTMENT
NO OBJECTION CERTIFICATE



building during the first 02 Years and there after once in 6 months as per Clause D-3 in annex. D of Part IV NBC of India 2016.

15. It is informed that, you may please note that the builder along with Architect and site Engineer shall be held responsible for any deviations from the Revised provisional No Objection Certificate issued and necessary Legal Action will be initiated as per provisions of Fire Service Act.

16. The Revised Provisional No Objection Certificate is issued with an advice that Non Multi Storied Building should not be occupied and the operation should not be commenced without obtaining the No Objection certificate for occupancy from this Department about the satisfactory installation of above fire safety measures.

Hence Provisional No Objection Certificate issued earlier vide reference 1st cited is cancelled.

17. Additional Fire Safety Measures Recommended by the Department:

0



Signed By : B.Harinatha Reddy

Designation : Regional Fire Officer, Multi Zone-2.

Date : 09-02-2025

Fire, Disaster Response, Emergency & Civil Defence Department,
Telangana, Hyderabad.

Copies to:

- i) The Management
- ii) Multistoried Building Inspection Committee
- iii) Copy submitted to Regional Fire officer
- iv) Copy submitted to DG fire services

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"